



Diamond Series UPS (Extended Battery Cabinet Runtimes)

Diamond Series 10kVA Battery Backup Runtimes				
Load %	100% Load	50% Load	25% Load	10% Load
Internal Batteries Only	3 minutes	10 minutes	26 minutes	82 minutes

Diamond Series 15kVA Battery Backup Runtimes				
Load %	100% Load	50% Load	25% Load	10% Load
Internal Batteries Only	5 minutes	15 minutes	28 minutes	116 minutes

Diamond Series 20kVA Battery Backup Runtimes				
Load %	100% Load	50% Load	25% Load	10% Load
Internal Batteries Only	6 minutes	18 minutes	44 minutes	134 minutes

Diamond Series 30kVA Battery Backup Runtimes				
Load %	100% Load	50% Load	25% Load	10% Load
Internal Batteries Only	4 minutes	13 minutes	33 minutes	95 minutes

Diamond Series 40kVA Battery Backup Runtimes				
Load %	100% Load	50% Load	25% Load	10% Load
Internal Batteries Only	4 minutes	13 minutes	33 minutes	95 minutes